

## CE – Declaration of Conformity

Document: CE-UKCA250903C\_Sense Pro X  
 Product Inspection: PI250902A  
 Risk Assessment: RA240904A

We, **SG Armaturen AS**  
**Skytterheia 25**  
**N-4790 Lillesand - Norway**

declare under sole responsibility that the product

**Luminaire**

Type

**Sense Pro X**

Name(s)

To which this declaration relates is in conformity with the following EC-directive(s):

<i>Directive 2014 / 30 / EU</i>	<i>Directive 2014 / 35 / EU</i>	<i>Directive 2009 / 125 / EF</i>
Electromagnetic compatibility (EMC)	Low Voltage directive (LVD)	(Regs 244/2009, 245/2009, 347/2010)* Ecodesign requirements (ECO) * As applicable and including amendments

*RoHS 2011 / 65 / EU + RoHS III / EU 2015/863*

The conformity of the product with the provisions of the directives is stated by the compliance with the following standards:

<b>EN 60598-1:2021+A11:2022</b>	(Luminaires - General requirements)
<b>EN 60598-2-2:2012</b>	(Luminaires - Recessed)
<b>EN 60598-2-22:2022</b>	(Luminaires – emergency lighting)
<b>EN 62471:2008</b>	(Luminaires – Photobiological safety of lamps and lamp systems)
<b>EN 62493:2015</b>	(EMF – Lighting equipment related to human exposure)
<b>EN 55015:2019+A11:2020</b>	<b>(EMC - Radio disturbance)</b>
<b>EN 61000-3-2:2019</b>	<b>(EMC - Harmonics)</b>
<b>EN 61000-3-3:2013+A1:2019</b>	<b>(EMC – Voltage change, fluctuation &amp; flicker)</b>
<b>EN 61547:2009</b>	(EMC - Immunity)


CE declaration date: 2025

Statement of Conformity

issued by SG Armaturen AS

**Manufacturer**  
Lillesand, 03/09-2025  
 Place and date of issue

Martin Ettrup  
Approval Engineer  
 Name of authorized person

  
 Signature of authorized person

## UKCA – Declaration of Conformity

Document: CE-UKCA250903C\_Sense Pro X  
 Product Inspection: PI250902A  
 Risk Assessment: RA240904A

We, **SG Armaturen AS**  
**Skytterheia 25**  
**N-4790 Lillesand - Norway**

declare under sole responsibility that the product

**Luminaire**

Type

**Sense Pro X**

Name(s)

To which this declaration relates is in conformity with the following UK-regulations:

<i>UK SI 2016 No. 1091</i>	<i>UK SI 2016 No. 1101</i>	<i>UK SI 2010 No. 2617</i>	<i>UK SI 2012 No. 3032</i>
The Electromagnetic Compatibility Regulations 2010	The Electrical Equipment (Safety) Regulations 2016	The Ecodesign for Energy-Related Products Regulations 2010 Equipment (Safety) Regulations 2016	The Restriction of the Use of Certain Hazardous Substances in Electrical Equipment Regulations 2012

The conformity of the product with the provisions of the directives is stated by the compliance with the following standards:

<b>EN 60598-1:2021+A11:2022</b>	(Luminaires - General requirements)
<b>EN 60598-2-2:2012</b>	(Luminaires - Recessed)
<b>EN 60598-2-22:2022</b>	(Luminaires – emergency lighting)
<b>EN 62471:2008</b>	(Luminaires – Photobiological safety of lamps and lamp systems)
<b>EN 62493:2015</b>	(EMF – Lighting equipment related to human exposure)
<b>EN 55015:2019+A11:2020</b>	<b>(EMC - Radio disturbance)</b>
<b>EN 61000-3-2:2019</b>	<b>(EMC - Harmonics)</b>
<b>EN 61000-3-3:2013+A1:2019</b>	<b>(EMC – Voltage change, fluctuation &amp; flicker)</b>
<b>EN 61547:2009</b>	(EMC - Immunity)
<b>UK SI 2021 No. 1095</b>	(Luminaires – The Ecodesign for Energy-Related products and Energy Information)


UKCA declaration date: 2025

Statement of Conformity

issued by SG Armaturen AS

**Manufacturer**  
Lillesand, 03/09-2025  
 Place and date of issue

Martin Ettrup  
 Approval Engineer  
 Name of authorized person

  
 Signature of authorized person

Declaration of Conformity statements/valid for the following products:

Product ID Number	Product Description	Article type	Article group
7021982126604	Sense Pro X 600x600 White Incl driver 3980lm	3000K Ra>80 DALI-2	703180
7021982126611	Sense Pro X 600x600 White Incl driver 4120lm	4000K Ra>80 DALI-2	703180

#### Emergencybox

5703821177344	Emergencybox Driver	DALI / EM Emergency 3 hours DALI	
5703821177276	Emergencybox	On-Off/Trailing edge / EM Self-test, Emergency 3 hours	
5703821177504	Emergencybox Driver	DALI / EM DALI/Self-test, Emergency 3 hours	