



CE – Declaration of Conformity

Document: CE-UKCA240105D_Sense Eco Opalprism
Product Inspection: PI240104A
Risk Assessment: RA210225C

We, **SG Armaturen AS**
Skytterheia 25
N-4790 Lillesand - Norway

declare under sole responsibility that the product

Luminaire

Type

Sense Eco Opalprism

Name(s)

To which this declaration relates is in conformity with the following EC-directive(s):

<i>Directive 2014 / 30 / EU</i>	<i>Directive 2014 / 35 / EU</i>	<i>Directive 2009 / 125 / EF</i>
Electromagnetic compatibility (EMC)	Low Voltage directive (LVD)	(Regs 244/2009, 245/2009, 347/2010)* Ecodesign requirements (ECO) * As applicable and including amendments

RoHS 2011 / 65 / EU + RoHS III / EU 2015/863

The conformity of the product with the provisions of the directives is stated by the compliance with the following standards:

- EN 60598-1:2021+A11:2022** (Luminaires - General requirements)
- EN 60598-2-2:2012** (Luminaires - Recessed)
- EN 60598-2-22:2014** (Luminaires – emergency lighting)
- EN 62471:2008** (Luminaires – Photobiological safety of lamps and lamp systems)
- EN 62493:2015** (EMF – Lighting equipment related to human exposure)
- EN 55015:2019+A11:2020** (EMC - Radio disturbance)
- EN 61000-3-2:2019** (EMC - Harmonics)
- EN 61000-3-3:2013+A1:2019** (EMC – Voltage change, fluctuation & flicker)
- EN 61547:2009** (EMC - Immunity)

CE declaration date: 2024

Statement of Conformity

issued by SG Armaturen AS

Manufacturer
Lillesand, 05/01-2024
Place and date of issue

Martin Ettrup
Approval Engineer
Name of authorized person

Signature of authorized person



UKCA – Declaration of Conformity

Document: CE-UKCA240105D_Sense Eco Opalprism
Product Inspection: PI240104A
Risk Assessment: RA210225C

We, **SG Armaturen AS**
Skytterheia 25
N-4790 Lillesand - Norway

declare under sole responsibility that the product

Luminaire

Type

Sense Eco Opalprism

Name(s)

To which this declaration relates is in conformity with the following UK-regulations:

<i>UK SI 2016 No. 1091</i>	<i>UK SI 2016 No. 1101</i>	<i>UK SI 2010 No. 2617</i>	<i>UK SI 2012 No. 3032</i>
The Electromagnetic Compatibility Regulations 2010	The Electrical Equipment (Safety) Regulations 2016	The Ecodesign for Energy-Related Products Regulations 2010 Equipment (Safety) Regulations 2016	The Restriction of the Use of Certain Hazardous Substances in Electrical Equipment Regulations 2012

The conformity of the product with the provisions of the directives is stated by the compliance with the following standards:

- EN 60598-1:2021+A11:2022** (Luminaires - General requirements)
- EN 60598-2-2:2012** (Luminaires - Recessed)
- EN 60598-2-22:2014** (Luminaires – emergency lighting)
- EN 62471:2008** (Luminaires – Photobiological safety of lamps and lamp systems)
- EN 62493:2015** (EMF – Lighting equipment related to human exposure)
- EN 55015:2019+A11:2020** (EMC - Radio disturbance)
- EN 61000-3-2:2019** (EMC - Harmonics)
- EN 61000-3-3:2013+A1:2019** (EMC – Voltage change, fluctuation & flicker)
- EN 61547:2009** (EMC - Immunity)
- UK SI 2021 No. 1095** (Luminaires – The Ecodesign for Energy-Related products and Energy Information)

UKCA declaration date: 2024

Statement of Conformity

issued by SG Armaturen AS

Manufacturer
Lillesand, 05/01-2024
Place and date of issue

Martin Ettrup
Approval Engineer
Name of authorized person

Martin Ettrup
Signature of authorized person



Declaration of Conformity statements/valid for the following products:

Product ID Number	Product Description	Article type	Article group
7021982122231	Sense ECO 600x600 White Opalprism	4000K Ra>80	701569
7021982122224	Sense ECO 600x600 White Opalprism	3000K Ra>80	701569
Drivers			
7021988200834	Sense Driver White	3000lm 26W 700mA DALI / Push Dim	
7021988204900	Sense Driver White	3000lm 26W 700mA Trailing edge dimming	
7021988204917	Sense Driver White	3000lm 26W 700mA Trailing edge dimming	
Emergencybox			
5703821177344	Emergencybox Driver	DALI / EM Emergency 3 hours DALI	
5703821177276	Emergencybox	On-Off/Trailing edge / EM Self test, Emergency 3h	
5703821177504	Emergencybox Driver	DALI / EM DALI/Self test, Emergency 3 hours	