



CE – Declaration of Conformity

Document: CE200306A_Jupiter Pro Emergency Kit
 Product Inspection: PI190410A
 Risk Assessment: RA190412A

We, **SG Produktion A/S**
Egestubben 16-26
DK-5270 Odense N - Denmark

declare under sole responsibility that the product

Remote control gear emergency

Type

EM Box

Name(s)

To which this declaration relates is in conformity with the following EC-directive(s):

<i>Directive 2014 / 30 / EU</i>	<i>Directive 2014 / 35 / EU</i>	<i>RoHS 2011 / 65 / EU</i> + <i>RoHS III / EU 2015/863</i>
Electromagnetic compatibility (EMC)	Low Voltage directive (LVD)	

The conformity of the product with the provisions of the directives is stated by the compliance with the following standards:

EN 60598-1:2015	(Luminaires - General requirements)
EN 60598-2-2:2012	(Luminaires - Recessed)
EN 60598-2-22:2014	(Luminaires – emergency lighting)
EN 55015:2013 + A1:2015	(EMC - Radio disturbance)
EN 61000-3-2:2014	(EMC - Harmonics)
EN 61000-3-3:2013	(EMC – Voltage change, fluctuation & flicker)
EN 61547:2009	(EMC - Immunity)

The luminaire (Jupiter Pro) in combination with the Emergency Kit had been tested and comply with the requirements of 3 hours of emergency battery supply.

Reference test report: TH200305A

CE Marking date: 2020

Statement of Conformity

issued by SG Produktion A/S

Manufacturer

Odense, 06/03-2020
Place and date of issue

Martin Etrup

Name of authorized person

Signature of authorized person



Declaration of Conformity statements/valid for the following products:

Product ID Number

8246094500
8246094429
8246094364

Product Description

Independent emergency light box 3 hours
Independent emergency light box 3 hours
Independent emergency light box 3 hours

Article type

DALI Emergency 3H DALI adr.
DALI Emergency 3H
Emergency 3H

